

## Annexure C

### PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 105/UJS/SDLW&TML/2025-26

Dated: 02/06/2025

It is certified that an inspection team headed by SDLW&TML UJS, Vikasnagar.....

(Name of Officers with designation) from Alendra Singh..... PHED

inspected the Sanskar World School, Katra Kalyanpur, Dehradun

(Name & Address of the school) on 31/05/2025.....(date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 105/UJS/SDLW&TML/2025-26 dated 02/06/2025...

of SDLW&TML UJS, Vikasnagar..... (PHED Lab) certified that the

Sanskar World School, Katra Kalyanpur, (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 01/06/2026.....

Signature with Seal:  SDLW&TML UJS, Vikasnagar

Name : Alendra Singh.....

Designation : .....

Name & Address of the Office / Department : .....

To

Sanskar World School,  
Katra Kalyanpur, Dehradun  
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



**NABL Recognized**  
**Sub Divisional Level Water Quality Testing and Monitoring Laboratory**  
**Uttarakhand Jal Sansthan, Vikasnagar**  
**Government Drinking Water Testing Laboratory**  
Ph (O): 01360-250345, E-mail: jalkallab@gmail.com

Test Report ID: 105/UJS/SDLWQTM/2025-26

Dated: 02/06/2025

**WATER QUALITY TEST REPORT**

Name and Address of Organization/ Customer	Sanskar World School Kotra Kalyanpur Dehradun		
Product Description (Surface Water/ Ground Water/ Drinking Water)	Drinking Water	Sample Description	One Water Sample collected from <b>Sanskar World School</b>
Reference Sample Identification:	SDLWQTM/UJS/2025-26-105		Date of Start of Analysis: 31/05/2025
			Date of End of Analysis: 02/06/2025
Date and Time of Sample Received: 31/05/25 & 01:30PM	Sample Collected by:		Customer

SN	Water Quality Parameters Under Chemical eScope	Results	Desirable Limit (BIS)	Permissible Limit (BIS) in the Absence of alternative source	Std. Test Method
1.	pH	7.29	6.5 to 8.5	No Relaxation	IS 3025 Pt-11, 2022
2.	Total Dissolved Solids (TDS), mg/L	82	500	2000	IS 3025 Pt-16-2023
3.	Turbidity, NTU	1.21	1	5	IS 3025 Pt-10-2023
4.	Total Alkalinity (as CaCO <sub>3</sub> ), mg/L	48	200	600	IS 3025 Pt-23: 2023
5.	Total Hardness (as CaCO <sub>3</sub> ), mg/L	62	200	600	IS 3025 Pt-21: 2009 Ra, 2019
6.	Chloride, mg/l	5.98	250	1000	IS 3025 Pt-32 : 2019
7.	Calcium (as Ca), mg/L	20.8	75	200	IS 3025 Pt-40 : 2023
8.	Magnesium (as Mg), mg/L	2.43	30	100	APHA 23rd Ed.-3500-Mg B: 2023
9.	Colour, Hazen	01	5	15	IS 3025 Pt-04 : 2021
10.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 Pt-05 : 2022
11.	Taste	Agreeable	Agreeable	Agreeable	IS 3025 Pt-08 : 2012

(Er. J.S. Chaudhary)  
Quality Manager  
SDWQTM, LAB

Uttarakhand Jal Sansthan  
Vikasnagar

-End of Report-

1. The results listed refer only to tested sample and applicable parameters.
2. This certificate is not to be reproduced wholly or in parts for promotional publicity or legal purpose without permission of authority of testing laboratory.
3. The samples will be destroyed after fifteen days from the date of issue of test certificate, unless otherwise agreed with customer.



Sub Divisional Level Water Quality Testing and Monitoring Laboratory  
Uttarakhand Jal Sansthan, Vikasnagar.  
Ph (O): 9258186962, E-mail: jalkallab@gmail.com

Report ID: 105/UJS/SDLWQTML/2025-26

Dated: 02/06/2025

**WATER QUALITY TEST REPORT**

Name and Address of Organization/ Customer	Sanskar World School Kotra Kalyanpur Dehradun				
Product Description (Surface Water/ Ground Water/ Drinking Water)	Drinking Water	Sample Description	One Water Sample Collected From Sanskar World School		
Reference Sample Identification:	SDLWQTML/UJS/2025-26-105		Date of Start of Analysis: 31/05/2025		
			Date of End of Analysis: 02/05/2025		
Date and Time of Sample Received: 31/05/25 & 01:30 PM		Sample Collected by:	Customer		

SN	Water Quality Parameters Under Chemical Scope	Results	Desirable Limit (BIS)	Permissible Limit (BIS) in the Absence of alternative source	Std. Test Method
1	Total Coliform, MPN/100ml	Absent	Absent	Absent	APHA 23 rd Ed.-9223-B
2	E.Coli, MPN/100ml	Absent	Absent	Absent	APHA 23 rd Ed.-9223-B
3	Residual Free Chlorine, mg/L	0.0	0.2	1.0	IS 3025 Pt-26:1986

(Er. J. S. Chauhan)

Quality Manager  
SDWQTM, LAB

Uttarakhand Jal Sansthan

-End of Report-

1. The results listed refer only to tested sample and applicable parameters.
2. This certificate is not to be reproduced wholly or in parts for promotional publicity or legal purpose without permission of authority of testing laboratory.
3. The samples will be destroyed after fifteen days from the date of issue of test certificate, unless otherwise agreed with customer.



**“जल संचय-जीवन संचय”**  
**कार्यालय सहायक अभियन्ता, उत्तराखण्ड जल संस्थान**  
**सहसपुर (देहरादून)**



ई-मेल :- spursubdiv@gmail.com

दूरभाष :- 0135-2983939

**प्रमाण पत्र**

प्रमाणित किया जाता है कि संस्कार वर्ल्ड स्कूल, कोटड़ा कल्याणपुर, बिरसनी, देहरादून को विभाग द्वारा श्री राकेश कुमार पुत्र श्री हीरा सिंह के नाम से अघरेलू पेयजल संयोजन निर्गत है, जिसमें मानकों के अनुसार शुद्ध पेयजल आपूर्ति की जा रही है।

सहायक अभियन्ता